



- NOTES:
1. FOR REFERENCE CELL ASSEMBLIES LOCATED OUT OF TRAFFIC AREAS, REFER TO DRAWING STD-04-00001_06.
 2. JUNCTION BOXES SHALL NOT BE FIXED TO THE STREET BOX AND SUFFICIENT CABLE SLACK PROVIDED TO REMOVE BOXES (MIN. 500mm) OUT OF THE STREET BOX FOR TESTING.
 3. FOR WIRING DETAILS SEE DRAWING STD-04-00001_06.
 4. REFERENCE CELL CABLE SHIELD SHALL BE EARTHED TO EARTH STRIP AT TR UNIT.
 5. CAST IRON CHAMBER AS PER DRAWING 4005-30007-01.
 6. CAST IRON STREET BOX SHALL BE SET TO THE FINISHED SURFACE LEVEL OR SLOPE OF THE ROAD

REVISION PANEL					DESIGN PANEL			<div></div> <div>This drawing is the property of the SOUTH AUSTRALIAN WATER CORPORATION and shall not be copied or modified in part or in whole without authorization.</div>		SA WATER STANDARD DRAWING STANDARD CATHODIC PROTECTION REFERENCE CELL ASSEMBLY CATHODIC PROTECTION (PAVED AREAS)			A3 SHT SIZE		TOTAL SHEETS: PROJECT No: X00002		1.0 REVISION	
REV	DATE	DRN	DETAILS	APR	CURRENT REV 03/06/22	DESIGNED: 03/06/2022	AUTHORISED:			MAXIMO ID:	SUPERSEDES:		DRAWING NUMBER					
					AUTHORISED:	R. SALAZAR ROMERO	KINGSLEY BROWN											
					SIGNATURE:	C. DOUGALL	SIGNATURE:											
					ORIGINAL SIGNED	REVIEWED: 03/06/2022	ORIGINAL SIGNED											
1.0	03/06/22	CD	ISSUED FOR USE	RSR		KINGSLEY BROWN					STD-04-00001_07							
CURRENT REV CONTRACTOR:					CURRENT REV PROJECT:			CONTRACTOR:										